

July 17, 2019

Mike Nickerson, CHMM Environmental/Safety Coordinator Central Bucks School District 320 West Swamp Road Doylestown, PA 18901

Re: Lead in Drinking Water Sample Collection and Reporting Cold Spring Elementary School
4150 Durham Road
Doylestown, PA 18902
Bucks County, Pennsylvania

Dear Mr. Nickerson:

This document has been prepared by Langan to provide the results of the drinking water sampling activities at the above referenced school. Langan sampled the drinking water sources (e.g. fountains, sink faucets, etc.) as identified by the Central Bucks School District facility inventory. The collected samples were sent to the Pennsylvania certified environmental laboratory, PACE Analytical, and analyzed for total lead by USEPA Method 200.8, to meet Pennsylvania's action level requirements.

The results did not detect any exceedances at this school of the Pennsylvania Action Level of 15 micrograms per liter (ug/L) with the exception of the following locations:

LocationSample IDResultLibrary work room11115.2 ug/L

As requested by Mike Nickerson, here is a list of locations with lead results above 10 ug/L, but below Pennsylvania Action Level of 15 ug/L are as follows:

LocationSample IDResultRm 109 faculty room10910.0 ug/L

A field sketch of the sampling locations and copy of the laboratory report is attached.

Sincerely,

Langan Engineering & Environmental Services, Inc.

John V. Musco

Associate

Enclosure

cc: R. Copenhaver, PG – Langan

B. Lambing. - Langan

Tyler Arinder – Langan NJ Certificate of Authorization No. 24GA27996400

\langan.com\data\DYL\data4\200130401\Project Data\Record Data\Reports\Day 6_6-12-19 East Cold Spring Buck\Cold Spring_Lead_Sampling_Memo.docx







June 26, 2019

Randy Copenhaver Langan Engineering 2700 Kelly Road, Suite 200 Warrington, PA 18976

RE: Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Dear Randy Copenhaver:

Enclosed are the analytical results for sample(s) received by the laboratory on June 14, 2019. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

John D. Stanton

Joh Shu

john.stanton@pacelabs.com

(631)694-3040 Project Manager

Enclosures

cc: Bill Lambing, Langan Engineering





575 Broad Hollow Road Melville, NY 11747 (631)694-3040



CERTIFICATIONS

Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158 Pennsylvania Certification #: 68-00350 Connecticut Certification #: PH-0435 Maryland Certification #: 208

Rhode Island Certification #: LAO00340 Massachusetts Certification #: M-NY026 New Hampshire Certification #: 2987



Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Date: 06/26/2019 04:43 PM

Pace Project No.: 7094027								
Sample: 131A	Lab ID: 709	4027001	Collected: 06/12/1	19 05:42	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	0.8					
Lead	7.3	ug/L	1.0	1		06/25/19 17:5	55 7439-92-1	
Sample: 138A	Lab ID: 709	4027002	Collected: 06/12/1	19 05:37	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	0.8					
Lead	2.8	ug/L	1.0	1		06/25/19 17:5	59 7439-92-1	
Sample: 100C	Lab ID: 709	4027003	Collected: 06/12/1	19 05:39	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	0.8					
Lead	2.3	ug/L	1.0	1		06/25/19 18:0	08 7439-92-1	
Sample: 101	Lab ID: 709	4027004	Collected: 06/12/1	19 05:43	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	0.8					
Lead	2.2	ug/L	1.0	1		06/25/19 18:1	11 7439-92-1	
Sample: 102	Lab ID: 709	4027005	Collected: 06/12/1	19 05:44	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	0.8					
Lead	1.2	ug/L	1.0	1		06/25/19 18:1	14 7439-92-1	
Sample: 103	Lab ID: 709	4027006	Collected: 06/12/1	19 05:44	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	0.8					
Lead	1.4	ug/L	1.0	1		06/25/19 18:1	17 7439-92-1	



Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Date: 06/26/2019 04:43 PM

Pace Project No.: 7094027								
Sample: 104	Lab ID: 709	4027007	Collected: 06/12/	19 05:45	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	00.8					
Lead	1.3	ug/L	1.0	1		06/25/19 18:2	20 7439-92-1	
Sample: 105	Lab ID: 709	4027008	Collected: 06/12/	19 05:46	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	00.8					
Lead	2.0	ug/L	1.0	1		06/25/19 18:2	29 7439-92-1	
Sample: 106	Lab ID: 709	4027009	Collected: 06/12/	19 05:46	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	00.8					
Lead	1.2	ug/L	1.0	1		06/25/19 18:3	32 7439-92-1	
Sample: 107	Lab ID: 709	4027010	Collected: 06/12/	19 05:48	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	00.8					
Lead	1.4	ug/L	1.0	1		06/25/19 18:3	35 7439-92-1	
Sample: 108	Lab ID: 709	4027011	Collected: 06/12/	19 05:48	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	00.8					
Lead	1.5	ug/L	1.0	1		06/25/19 18:4	14 7439-92-1	
Sample: 131FA	Lab ID: 709	4027012	Collected: 06/12/	19 05:40	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	00.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 18:4	17 7439-92-1	



Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Date: 06/26/2019 04:43 PM

Pace Project No.: 7094027								
Sample: 131FB	Lab ID: 709	4027013	Collected: 06/12/	19 05:40	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	00.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 18:5	50 7439-92-1	
Sample: 109	Lab ID: 709	4027014	Collected: 06/12/	19 06:06	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	00.8					
Lead	10.0	ug/L	1.0	1		06/25/19 18:5	53 7439-92-1	
Sample: 111	Lab ID: 709	4027015	Collected: 06/12/	19 05:51	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	00.8					
Lead	15.2	ug/L	1.0	1		06/25/19 18:5	56 7439-92-1	
Sample: 130	Lab ID: 709	4027016	Collected: 06/12/	19 05:50	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	00.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 18:5	59 7439-92-1	
Sample: 129	Lab ID: 709	4027017	Collected: 06/12/	19 05:53	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	00.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 19:0	08 7439-92-1	
Sample: 128	Lab ID: 709	4027018	Collected: 06/12/	19 05:55	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	00.8					
Lead	3.3	ug/L	1.0	1		06/25/19 19:2	24 7439-92-1	



Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Date: 06/26/2019 04:43 PM

Pace Project No.: 7094027								
Sample: 128A	Lab ID: 709	4027019	Collected: 06/12/1	19 05:56	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 200	0.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 19:2	27 7439-92-1	
Sample: 117	Lab ID: 7094	4027020	Collected: 06/12/1	19 05:59	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 200	0.8					
Lead	2.8	ug/L	1.0	1		06/25/19 19:3	30 7439-92-1	
Sample: 118	Lab ID: 7094	4027021	Collected: 06/12/1	19 05:59	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 200	0.8					
Lead	3.0	ug/L	1.0	1		06/25/19 19:3	33 7439-92-1	
Sample: 119	Lab ID: 7094	4027022	Collected: 06/12/1	19 06:00	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 200	0.8					
Lead	1.2	ug/L	1.0	1		06/25/19 19:3	36 7439-92-1	
Sample: 120	Lab ID: 7094	4027023	Collected: 06/12/1	19 06:00	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 200	0.8					
Lead	1.1	ug/L	1.0	1		06/25/19 19:3	39 7439-92-1	
Sample: 121	Lab ID: 7094	4027024	Collected: 06/12/1	19 06:02	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 200	0.8					<u>-</u>
Lead	<1.0	ug/L	1.0	1		06/25/19 19:4	12 7439-92-1	



Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Date: 06/26/2019 04:43 PM

Pace Project No.: 7094027								
Sample: 122	Lab ID: 709	4027025	Collected: 06/12/1	19 06:02	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	0.8					
Lead	1.1	ug/L	1.0	1		06/25/19 19:4	15 7439-92-1	
Sample: 123	Lab ID: 709	4027026	Collected: 06/12/1	19 06:04	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	0.8					
Lead	1.3	ug/L	1.0	1		06/25/19 19:4	18 7439-92-1	
Sample: 124	Lab ID: 709	4027027	Collected: 06/12/1	19 06:04	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Met	hod: EPA 20	0.8					
Lead	1.4	ug/L	1.0	1		06/25/19 19:5	57 7439-92-1	
Sample: 201	Lab ID: 709	4027028	Collected: 06/12/1	19 06:08	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	0.8					
Lead	3.4	ug/L	1.0	1		06/25/19 20:0	06 7439-92-1	
Sample: 202	Lab ID: 709	4027029	Collected: 06/12/1	19 06:08	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	0.8					
Lead	1.4	ug/L	1.0	1		06/25/19 20:0	09 7439-92-1	
Sample: 203	Lab ID: 709	4027030	Collected: 06/12/1	19 06:10	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Metl	hod: EPA 20	0.8					
Lead	3.4	ug/L	1.0	1		06/25/19 20:1	12 7439-92-1	



Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Date: 06/26/2019 04:43 PM

Pace Project No.: 7094027								
Sample: 204	Lab ID: 709	4027031	Collected: 06/12/1	9 06:10	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 200	0.8					
Lead	1.5	ug/L	1.0	1		06/25/19 20:1	15 7439-92-1	
Sample: 205	Lab ID: 709	4027032	Collected: 06/12/1	9 06:11	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 200	0.8					
Lead	2.2	ug/L	1.0	1		06/25/19 20:1	18 7439-92-1	
Sample: 206	Lab ID: 709	4027033	Collected: 06/12/1	9 06:11	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 200	0.8					
Lead	1.1	ug/L	1.0	1		06/25/19 20:2	21 7439-92-1	
Sample: 207	Lab ID: 709	4027034	Collected: 06/12/1	9 06:12	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 200	0.8					
Lead	1.4	ug/L	1.0	1		06/25/19 20:2	25 7439-92-1	
Sample: 208	Lab ID: 709	4027035	Collected: 06/12/1	9 06:12	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 200	0.8					
Lead	2.3	ug/L	1.0	1		06/25/19 20:3	34 7439-92-1	
Sample: 231A	Lab ID: 709	4027036	Collected: 06/12/1	9 06:14	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Metl	hod: EPA 20	0.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 20:3	37 7439-92-1	



Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Date: 06/26/2019 04:43 PM

Pace Project No.: 7094027								
Sample: 231B	Lab ID: 709	4027037	Collected: 06/12/	19 06:14	Received:	06/14/19 11:00	Matrix: Drinking	y Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	00.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 20:4	46 7439-92-1	
Sample: 211	Lab ID: 709	4027038	Collected: 06/12/	19 06:15	Received:	06/14/19 11:00	Matrix: Drinking	g Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Metl	hod: EPA 20	00.8					
Lead	1.5	ug/L	1.0	1		06/25/19 20:5	55 7439-92-1	
Sample: 215	Lab ID: 709	4027039	Collected: 06/12/	19 06:15	Received:	06/14/19 11:00	Matrix: Drinking	g Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Metl	hod: EPA 20	00.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 20:5	58 7439-92-1	
Sample: 227A	Lab ID: 709	4027040	Collected: 06/12/	19 06:17	Received:	06/14/19 11:00	Matrix: Drinking	g Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Metl	hod: EPA 20	00.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 21:0	01 7439-92-1	
Sample: 227B	Lab ID: 709	4027041	Collected: 06/12/	19 06:17	Received:	06/14/19 11:00	Matrix: Drinking	g Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Metl	nod: EPA 20	00.8					
Lead	<1.0	ug/L	1.0	1		06/25/19 21:	10 7439-92-1	
Sample: 217	Lab ID: 709	4027042	Collected: 06/12/	19 06:19	Received:	06/14/19 11:00	Matrix: Drinking	g Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Metl	nod: EPA 20	00.8					



Project: CENTRAL BUCKS SCH (COLD SPRING

Pace Project No.: 7094027

Date: 06/26/2019 04:43 PM

Pace Project No.: 7094027								
Sample: 219	Lab ID: 709	4027043	Collected: 06/12/1	19 06:20	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	0.8					
Lead	1.8	ug/L	1.0	1		06/25/19 21:1	6 7439-92-1	
Sample: 220	Lab ID: 709	4027044	Collected: 06/12/1	19 06:20	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	0.8					
Lead	3.7	ug/L	1.0	1		06/25/19 21:1	9 7439-92-1	
Sample: 221	Lab ID: 709	4027045	Collected: 06/12/1	19 06:22	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	hod: EPA 20	0.8					
Lead	1.0	ug/L	1.0	1		06/25/19 21:2	22 7439-92-1	
Sample: 223	Lab ID: 709	4027046	Collected: 06/12/1	19 06:23	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Meth	nod: EPA 20	0.8					
Lead	2.0	ug/L	1.0	1		06/25/19 21:2	25 7439-92-1	
Sample: 224	Lab ID: 709	4027047	Collected: 06/12/1	19 06:23	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Met	hod: EPA 20	0.8					
Lead	1.3	ug/L	1.0	1		06/25/19 21:2	28 7439-92-1	
Sample: 222	Lab ID: 709	4027048	Collected: 06/12/1	19 06:22	Received:	06/14/19 11:00	Matrix: Drinking	Water
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Metl	hod: EPA 20	0.8					
Lead	1.3	ug/L	1.0	1		06/25/19 21:3	88 7439-92-1	