

August 4, 2021

Thomas M. Hanna, P.E., LEED AP
Capital Projects Manager
Central Bucks School District
320 West Swamp Road
Doylestown, PA 18901

**Re: Lead in Drinking Water Sample Collection and Reporting
Holicong Middle School
2900 Township 391 Hwy
Doylestown, PA 18902**


Dear Mr. Hanna:

This document has been prepared by Langan to provide the results of the drinking water sampling activities at the above referenced school. Langan sampled the drinking water sources (e.g. bottle fillers, fountains, sink faucets, etc.) on July 2, 2021 as identified by the Central Bucks School District facility inventory. The collected samples were sent to the Pennsylvania certified environmental laboratory, PACE Analytical, and analyzed for total lead by USEPA Method 200.8, to meet Pennsylvania's action level requirements.

The results did not detect any exceedances at this school of the Pennsylvania Action Level of 15 micrograms per liter (ug/L).

A figure of the sampling locations and copy of the laboratory report is attached.

Sincerely,
Langan Engineering & Environmental Services, Inc.



John V. Musco
Associate

Enclosure
cc: B. Lambing - Langan

NJ Certificate of Authorization No. 24GA27996400
\\langan.com\data\DYL\data4\200130403\Project Data\Record Data\Reports\Day 6_7-2-2021_West_West
Stad_Lenape_Doyle_Holicong\5th_Holicong\Holicong_Lead_Sampling_Report_2021.docx

July 14, 2021

Bill Lambing
Langan Engineering
2700 Kelly Road
Suite 200
Warrington, PA 18976

RE: Project: CENTRAL BUCKS (HOLICONG)
Pace Project No.: 70179819

Dear Bill Lambing:

Enclosed are the analytical results for sample(s) received by the laboratory on July 06, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Sophia Sparkes
sophia.sparkes@pacelabs.com
(631)694-3040
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: CENTRAL BUCKS (HOLICONG)

Pace Project No.: 70179819

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS (HOLICONG)
Pace Project No.: 70179819

Sample: 102A_070221	Lab ID: 70179819001	Collected: 07/02/21 10:48	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:17	7439-92-1	

Sample: 110A_070221	Lab ID: 70179819002	Collected: 07/02/21 10:50	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:18	7439-92-1	

Sample: 100F_070221	Lab ID: 70179819003	Collected: 07/02/21 10:51	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:18	7439-92-1	

Sample: 111A_070221	Lab ID: 70179819004	Collected: 07/02/21 10:52	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:19	7439-92-1	

Sample: 111B_070221	Lab ID: 70179819005	Collected: 07/02/21 10:52	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS (HOLICONG)

Pace Project No.: 70179819

Sample: 112_070221	Lab ID: 70179819006	Collected: 07/02/21 10:54	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		07/14/21 09:23	7439-92-1	
Sample: 113_070221	Lab ID: 70179819007	Collected: 07/02/21 10:55	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:24	7439-92-1	
Sample: 150A_070221	Lab ID: 70179819008	Collected: 07/02/21 10:46	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:25	7439-92-1	
Sample: 150B_070221	Lab ID: 70179819009	Collected: 07/02/21 10:46	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:26	7439-92-1	
Sample: 143A_070221	Lab ID: 70179819010	Collected: 07/02/21 10:43	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		07/14/21 09:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS (HOLICONG)
Pace Project No.: 70179819

Sample: 144A_070221	Lab ID: 70179819011	Collected: 07/02/21 10:41	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:30	7439-92-1	
Sample: 141A_070221	Lab ID: 70179819012	Collected: 07/02/21 10:33	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.4	ug/L	1.0	1		07/14/21 09:31	7439-92-1	
Sample: 141B_070221	Lab ID: 70179819013	Collected: 07/02/21 10:33	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:34	7439-92-1	
Sample: 141C_070221	Lab ID: 70179819014	Collected: 07/02/21 10:34	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:35	7439-92-1	
Sample: 141D_070221	Lab ID: 70179819015	Collected: 07/02/21 10:34	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS (HOLICONG)
Pace Project No.: 70179819

Sample: 141E_070221	Lab ID: 70179819016	Collected: 07/02/21 10:34	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:37	7439-92-1	

Sample: 141F_070221	Lab ID: 70179819017	Collected: 07/02/21 10:35	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:38	7439-92-1	

Sample: 141G_070221	Lab ID: 70179819018	Collected: 07/02/21 10:35	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:39	7439-92-1	

Sample: 140A_070221	Lab ID: 70179819019	Collected: 07/02/21 10:32	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:41	7439-92-1	M1

Sample: 140B_070221	Lab ID: 70179819020	Collected: 07/02/21 10:30	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS (HOLICONG)

Pace Project No.: 70179819

Sample: 140C_070221	Lab ID: 70179819021	Collected: 07/02/21 10:31	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:47	7439-92-1	

Sample: 126_070221	Lab ID: 70179819022	Collected: 07/02/21 10:24	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.4	ug/L	1.0	1		07/14/21 09:48	7439-92-1	

Sample: 126A_070221	Lab ID: 70179819023	Collected: 07/02/21 10:25	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:49	7439-92-1	

Sample: 126B_070221	Lab ID: 70179819024	Collected: 07/02/21 10:26	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:50	7439-92-1	

Sample: 126C_070221	Lab ID: 70179819025	Collected: 07/02/21 10:26	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS (HOLICONG)
Pace Project No.: 70179819

Sample: C4_070221	Lab ID: 70179819026	Collected: 07/02/21 10:22	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:52	7439-92-1	

Sample: 240_070221	Lab ID: 70179819027	Collected: 07/02/21 11:04	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:53	7439-92-1	

Sample: 240A_070221	Lab ID: 70179819028	Collected: 07/02/21 11:02	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:54	7439-92-1	

Sample: 240B_070221	Lab ID: 70179819029	Collected: 07/02/21 11:03	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:57	7439-92-1	

Sample: 240C_070221	Lab ID: 70179819030	Collected: 07/02/21 11:03	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 09:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS (HOLICONG)
Pace Project No.: 70179819

Sample: 218A_070221	Lab ID: 70179819031	Collected: 07/02/21 11:59	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 10:01	7439-92-1	

Sample: 218B_070221	Lab ID: 70179819032	Collected: 07/02/21 11:59	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 10:01	7439-92-1	

Sample: 207_070221	Lab ID: 70179819033	Collected: 07/02/21 11:08	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.4	ug/L	1.0	1		07/14/21 10:02	7439-92-1	

Sample: 207A_070221	Lab ID: 70179819034	Collected: 07/02/21 11:09	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 10:03	7439-92-1	

Sample: 207B_070221	Lab ID: 70179819035	Collected: 07/02/21 11:10	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 10:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS (HOLICONG)

Pace Project No.: 70179819

Sample: 207C_070221	Lab ID: 70179819036	Collected: 07/02/21 11:09	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 10:05	7439-92-1	

Sample: 207D_070221	Lab ID: 70179819037	Collected: 07/02/21 11:12	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/14/21 10:08	7439-92-1	

Sample: 230G_070221	Lab ID: 70179819038	Collected: 07/02/21 11:06	Received: 07/06/21 19:20	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		07/14/21 10:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: CENTRAL BUCKS (HOLICONG)
Pace Project No.: 70179819

QC Batch:	217497	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70179819001, 70179819002, 70179819003, 70179819004, 70179819005, 70179819006, 70179819007, 70179819008, 70179819009, 70179819010, 70179819011, 70179819012, 70179819013, 70179819014, 70179819015, 70179819016, 70179819017, 70179819018

METHOD BLANK: 1096201 Matrix: Water
Associated Lab Samples: 70179819001, 70179819002, 70179819003, 70179819004, 70179819005, 70179819006, 70179819007, 70179819008, 70179819009, 70179819010, 70179819011, 70179819012, 70179819013, 70179819014, 70179819015, 70179819016, 70179819017, 70179819018

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	07/14/21 09:11	

LABORATORY CONTROL SAMPLE: 1096202

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.8	102	85-115	

MATRIX SPIKE SAMPLE: 1096204

Parameter	Units	70179774001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	56.5	112	70-130	

MATRIX SPIKE SAMPLE: 1096206

Parameter	Units	70179819009 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	62.8	126	70-130	

SAMPLE DUPLICATE: 1096203

Parameter	Units	70179774001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1096205

Parameter	Units	70179819009 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: CENTRAL BUCKS (HOLICONG)

Pace Project No.: 70179819

QC Batch: 217498

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70179819019, 70179819020, 70179819021, 70179819022, 70179819023, 70179819024, 70179819025, 70179819026, 70179819027, 70179819028, 70179819029, 70179819030, 70179819031, 70179819032, 70179819033, 70179819034, 70179819035, 70179819036, 70179819037, 70179819038

METHOD BLANK: 1096209

Matrix: Water

Associated Lab Samples: 70179819019, 70179819020, 70179819021, 70179819022, 70179819023, 70179819024, 70179819025, 70179819026, 70179819027, 70179819028, 70179819029, 70179819030, 70179819031, 70179819032, 70179819033, 70179819034, 70179819035, 70179819036, 70179819037, 70179819038

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	07/14/21 09:40	

LABORATORY CONTROL SAMPLE: 1096210

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.9	108	85-115	

MATRIX SPIKE SAMPLE: 1096212

Parameter	Units	70179819019 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	67.3	134	70-130	M1

MATRIX SPIKE SAMPLE: 1096214

Parameter	Units	70179819029 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	63.5	127	70-130	

SAMPLE DUPLICATE: 1096211

Parameter	Units	70179819019 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1096213

Parameter	Units	70179819029 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: CENTRAL BUCKS (HOLICONG)

Pace Project No.: 70179819

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CENTRAL BUCKS (HOLICONG)

Pace Project No.: 70179819

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70179819001	102A_070221	EPA 200.8	217497		
70179819002	110A_070221	EPA 200.8	217497		
70179819003	100F_070221	EPA 200.8	217497		
70179819004	111A_070221	EPA 200.8	217497		
70179819005	111B_070221	EPA 200.8	217497		
70179819006	112_070221	EPA 200.8	217497		
70179819007	113_070221	EPA 200.8	217497		
70179819008	150A_070221	EPA 200.8	217497		
70179819009	150B_070221	EPA 200.8	217497		
70179819010	143A_070221	EPA 200.8	217497		
70179819011	144A_070221	EPA 200.8	217497		
70179819012	141A_070221	EPA 200.8	217497		
70179819013	141B_070221	EPA 200.8	217497		
70179819014	141C_070221	EPA 200.8	217497		
70179819015	141D_070221	EPA 200.8	217497		
70179819016	141E_070221	EPA 200.8	217497		
70179819017	141F_070221	EPA 200.8	217497		
70179819018	141G_070221	EPA 200.8	217497		
70179819019	140A_070221	EPA 200.8	217498		
70179819020	140B_070221	EPA 200.8	217498		
70179819021	140C_070221	EPA 200.8	217498		
70179819022	126_070221	EPA 200.8	217498		
70179819023	126A_070221	EPA 200.8	217498		
70179819024	126B_070221	EPA 200.8	217498		
70179819025	126C_070221	EPA 200.8	217498		
70179819026	C4_070221	EPA 200.8	217498		
70179819027	240_070221	EPA 200.8	217498		
70179819028	240A_070221	EPA 200.8	217498		
70179819029	240B_070221	EPA 200.8	217498		
70179819030	240C_070221	EPA 200.8	217498		
70179819031	218A_070221	EPA 200.8	217498		
70179819032	218B_070221	EPA 200.8	217498		
70179819033	207_070221	EPA 200.8	217498		
70179819034	207A_070221	EPA 200.8	217498		
70179819035	207B_070221	EPA 200.8	217498		
70179819036	207C_070221	EPA 200.8	217498		
70179819037	207D_070221	EPA 200.8	217498		
70179819038	230G_070221	EPA 200.8	217498		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY

The Chain-of-Custody is a

WO#: 70179819



ately.

Section A Required Client Information:	Section B Required Project Information:	Section C Invoice Information:	
Company: Langan Engineering	Report To: Bill Lambing	Attention: Bill Lambing	
Address: 2700 Kelly Road, Suite 200	Copy To:	Company Name: Langan Engineering	
Warrington, PA 18976		Address: 2700 Kelly Road, Suite 200	Regulatory Agency
Email: blaming@langan.com	Purchase Order #: 200130403-400-001	Pace Quote: See Langan-Pace MSA	
Phone: 215-491-6500 Fax: 2015-491-6501	Project Name: Central Bucks School District (Holicong)	Pace Project Manager: sophia.sparkes@pacelabs.com,	State / Location
Requested Due Date: Standard Turn Around (5 day)	Project #: 200130403	Pace Profile #: 7983	PA

ITEM #	SAMPLE ID One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Analyses Test Y/N	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	
				START		END				Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol				Other
				DATE	TIME	DATE	TIME													
1	102A_070221	DW		7/2/2021	1048	7/2/2021	1048	1		X							X			
2	110A_070221	DW		7/2/2021	1050	7/2/2021	1050	1		X							X			
3	100F_070221	DW		7/2/2021	1051	7/2/2021	1051	1		X							X			
4	111A_070221	DW		7/2/2021	1052	7/2/2021	1052	1		X							X			
5	111B_070221	DW		7/2/2021	1052	7/2/2021	1052	1		X							X			
6	112_070221	DW		7/2/2021	1054	7/2/2021	1054	1		X							X			
7	113_070221	DW		7/2/2021	1055	7/2/2021	1055	1		X							X			
8	150A_070221	DW		7/2/2021	1046	7/2/2021	1046	1		X							X			
9	150B_070221	DW		7/2/2021	1046	7/2/2021	1046	1		X							X			
10	143A_070221	DW		7/2/2021	1043	7/2/2021	1043	1		X							X			
11	144A_070221	DW		7/2/2021	1041	7/2/2021	1041	1		X							X			
12	141A_070221	DW		7/2/2021	1033	7/2/2021	1033	1		X							X			

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS		
	<i>Bill Lambing</i>	7/6/2021		<i>Bill Lambing</i>	7/6/2021	16:30			
	<i>Bill Lambing</i>	7/6/2021	16:30	<i>Bill Lambing</i>	7/6/2021	16:20			
	<i>Bill Lambing</i>	7/6/2021	19:20	<i>Bill Lambing</i>	7/6/2021	19:20	40	N	N Y

SAMPLER NAME AND SIGNATURE		TEMP in C Received on ice (Y/N) Custody Sealed Cooler (Y/N) Samples Intact (Y/N)
PRINT Name of SAMPLER:	Bill Lambing	
SIGNATURE of SAMPLER: <i>Bill Lambing</i>	7/6/2021	



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A	Section B	Section C
Required Client Information:	Required Project Information:	Invoice Information:
Company: Langan Engineering	Report To: Bill Lambing	Attention: Bill Lambing
Address: 2700 Kelly Road, Suite 200	Copy To:	Company Name: Langan Engineering
Warrington, PA 18976		Address: 2700 Kelly Road, Suite 200
Email: blambing@langan.com	Purchase Order #: 200130403-400-001	Pace Quote: See Langan-Pace MSA
Phone: 215-491-6500 Fax: 2015-491-6501	Project Name: Central Bucks School District (Holicong)	Pace Project Manager: sophia.sparkes@pacelabs.com
Requested Due Date: Standard Turn Around (5 day)	Project #: 200130403	Pace Profile #: 7983

ITEM #	SAMPLE ID <small>One Character per box, (A-Z, 0-9 /, -) Sample Ids must be unique</small>	MATRIX <small>Drinking Water Water Waste Water Product Soil/Solid Oil Wipe Air Other Tissue</small>	CODE <small>DW WT WW P SL OL WP AR OT TS</small>	COLLECTED	START DATE	END DATE	SAMPLER TEMP AT COLLECTION	# OF CONTAINERS	Requested Analysis Filtered (Y/N)													Residual Chlorine (Y/N)				
													Preservatives													
									DATE	TIME	DATE	TIME	Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other	Analyses Test		2007 Metals (PB)			
13	141B_070221	DW			7/2/2021	1033	7/2/2021	1033	1			X							X							
14	141C_070221	DW			7/2/2021	1034	7/2/2021	1034	1			X							X							
15	141D_070221	DW			7/2/2021	1034	7/2/2021	1034	1			X							X							
16	141E_070221	DW			7/2/2021	1034	7/2/2021	1034	1			X							X							
17	141F_070221	DW			7/2/2021	1035	7/2/2021	1035	1			X							X							
18	141G_070221	DW			7/2/2021	1035	7/2/2021	1035	1			X							X							
19	140A_070221	DW			7/2/2021	1032	7/2/2021	1032	1			X							X							
20	140B_070221	DW			7/2/2021	1030	7/2/2021	1030	1			X							X							
21	140C_070221	DW			7/2/2021	1031	7/2/2021	1031	1			X							X							
22	126_070221	DW			7/2/2021	1024	7/2/2021	1024	1			X							X							
23	126A_070221	DW			7/2/2021	1025	7/2/2021	1025	1			X							X							
24	126B_070221	DW			7/2/2021	1026	7/2/2021	1026	1			X							X							

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	Bill Lambing Pace Analytical	7/6/2021	15:31	Paul Bryner Pace Analytical	7/6/2021	11:20	
	Paul Bryner Pace Analytical	7/6/21	19:20	Paul Bryner Pace Analytical	7/6/21	16:20	
					7/6/21	19:20	

Page 16 of 19

SAMPLER NAME AND SIGNATURE		TEMP in C	Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
PRINT Name of SAMPLER:	Bill Lambing				
SIGNATURE of SAMPLER:	<i>Bill Lambing</i> 7/6/2021				



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A

Required Client Information:

Company: Langan Engineering
 Address: 2700 Kelly Road, Suite 200
 Warrington, PA 18976
 Email: blaming@langan.com
 Phone: 215-491-6500 Fax: 2015-491-6501
 Requested Due Date: Standard Turn Around (5 day)

Section B

Required Project Information:

Report To: Bill Lambing
 Copy To:
 Purchase Order #: 200130403-400-001
 Project Name: Central Bucks School District (Holicong)
 Project #: 200130403

Section C

Invoice Information:

Attention: Bill Lambing
 Company Name: Langan Engineering
 Address: 2700 Kelly Road, Suite 200
 Pace Quote: See Langan-Pace MSA
 Pace Project Manager: sophia.sparkes@pacelabs.com
 Pace Profile #: 7983

ITEM #	SAMPLE ID One Character per box. (A-Z, 0-9 / , -) Sample Ids must be unique	MATRIX Drinking Water Water Waste Water Product Soil/Solid Oil Wipe Air Other Tissue	CODE DW WT WW P SL OL WP AR OT TS	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives							Analyses Test Y/N 200.7 Metals (PB)	Requested Analysis Filtered (Y/N)												Residual Chlorine (Y/N)	
						START		END				Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol		Other													
						DATE	TIME	DATE	TIME																								
25	126C_070221	DW				7/2/2021	1026	7/2/2021	1026	1		X							X														
26	C4_070221	DW				7/2/2021	1022	7/2/2021	1022	1		X							X														
27	240_070221	DW				7/2/2021	1104	7/2/2021	1104	1		X							X														
28	240A_070221	DW				7/2/2021	1102	7/2/2021	1102	1		X							X														
29	240B_070221	DW				7/2/2021	1103	7/2/2021	1103	1		X							X														
30	240C_070221	DW				7/2/2021	1103	7/2/2021	1103	1		X							X														
31	218A_070221	DW				7/2/2021	1059	7/2/2021	1059	1		X							X														
32	218B_070221	DW				7/2/2021	1059	7/2/2021	1059	1		X							X														
33	207_070221	DW				7/2/2021	1108	7/2/2021	1108	1		X							X														
34	207A_070221	DW				7/2/2021	1109	7/2/2021	1109	1		X							X														
35	207B_070221	DW				7/2/2021	1110	7/2/2021	1110	1		X							X														
36	207C_070221	DW				7/2/2021	1109	7/2/2021	1109	1		X							X														

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	<i>Bill Lambing</i>	7/6/2021		<i>Paul Argen</i>	7/6/2021	16:00	
	<i>Paul Argen</i>	7/6/21	16:30	<i>Bill Lambing</i>	7/6/21	16:20	
	<i>Paul Argen</i>	7/6/21	19:20	<i>Bill Lambing</i>	7/6/21	19:30	

SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER:	Bill Lambing
SIGNATURE of SAMPLER:	<i>Bill Lambing</i> 7/6/2021

TEMP in C	Received on Ice (Y/N)	Cooler (Y/N)	Sealed (Y/N)	Cooler (Y/N)	Samples Intact (Y/N)
-----------	--------------------------	--------------	--------------	--------------	-------------------------



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Section A Required Client Information:		Section B Required Project Information:		Section C Invoice Information:	
Company: Langan Engineering		Report To: Bill Lambing		Attention: Bill Lambing	
Address: 2700 Kelly Road, Suite 200		Copy To:		Company Name: Langan Engineering	
Warrington, PA 18976		Purchase Order #: 200130403-400-001		Address: 2700 Kelly Road, Suite 200	
Email: blambing@langan.com		Project Name: Central Bucks School District (Holicong)		Pace Quote: See Langan-Pace MSA	
Phone: 215-491-6500	Fax 2015-491-6501	Project #: 200130403		Pace Project Manager: sophia.sparkes@pacelabs.com,	
Requested Due Date: Standard Turn Around (5 day)		Project #: 200130403		Pace Profile #: 7983	

Regulatory Agency
State / Location
PA

ITEM #	SAMPLE ID One Character per box. (A-Z, 0-9 / , -) Sample ids must be unique	MATRIX Drinking Water DW Water WT Waste Water WW Product P Soil/Solid SL Oil OL Wipe WP Air AR Other OT Tissue TS	CODE DW WT WW P SL OL WP AR OT TS	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives								Y/N	Requested Analysis Filtered (Y/N)												Residual Chlorine (Y/N)						
						START		END				Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other		Analyses Test	200.7 Metals (PB)																	
DATE	TIME	DATE	TIME																																				
37	207D_070221			DW	G	7/2/2021	1112	7/2/2021	1112		1		X								X																		
38	230G_070221			DW	G	7/2/2021	1106	7/2/2021	1106		1		X								X																		

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS																																
	<i>[Handwritten Signature]</i>	7/6/2021		<i>[Handwritten Signature]</i>	7/6/2021	11:12																																	
	<i>[Handwritten Signature]</i>	7/6/21	15:3	<i>[Handwritten Signature]</i>	7/6/21	1626																																	
	<i>[Handwritten Signature]</i>	7/6/21	1920	<i>[Handwritten Signature]</i>	7/6/21	1920																																	

SAMPLER NAME AND SIGNATURE		TEMP in C Received on ice (Y/N) Custody Sealed Cooler (Y/N) Samples Intact (Y/N)
PRINT Name of SAMPLER:		
SIGNATURE of SAMPLER: <i>[Handwritten Signature]</i>		



Sample Condition Upon Receipt

WO#: 70179819

Client Name: Lang

Project

PM: STS Due Date: 07/21/21
CLIENT: LAN-PACourier: Fed Ex UPS USPS Client Commercial Pace OtherTracking #: _____
Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes NoPacking Material: Bubble Wrap Bubble Bags Ziploc None OtherThermometer Used: T1091 Correction Factor: +0.0
Cooler Temperature(°C): 19.0 Cooler Temperature Corrected(°C): 19.0Temperature Blank Present: Yes No
Type of Ice: Wet Blue None
 Samples on ice, cooling process has begun
Date/Time 5035A kits placed in freezer _____Temp should be above freezing to 6.0°C
USDA Regulated Soil (N/A, water sample)Date and Initials of person examining contents: 19.7/16/21Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes NoDid samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

				COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.
Sufficient Volume: (Triple volume provided for	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		11.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input type="checkbox"/> Yes	<input type="checkbox"/> No		12.
-Includes date/time/ID, Matrix: SL <u>(WT)</u> OIL				
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	13.
pH paper Lot # <u>HCO28486</u>				Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH >9 Sulfide, NaOH >12 Cyanide)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis				Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot # _____ Residual chlorine strips Lot # _____				Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	15.
Lead Acetate Strips Lot # _____				
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____				

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted: _____

Date/Time: _____

Comments/ Resolution: _____

* PM (Project Manager) review is documented electronically in LIMS.