

July 17, 2019

Mike Nickerson, CHMM
Environmental/Safety Coordinator
Central Bucks School District
320 West Swamp Road
Doylestown, PA 18901

**Re: Lead in Drinking Water Sample Collection and Reporting
Jamison Elementary School
2090 Land Road
Jamison, PA 18929
Bucks County, Pennsylvania**


Dear Mr. Nickerson:

This document has been prepared by Langan to provide the results of the drinking water sampling activities at the above referenced school. Langan sampled the drinking water sources (e.g. fountains, sink faucets, etc.) as identified by the Central Bucks School District facility inventory. The collected samples were sent to the Pennsylvania certified environmental laboratory, PACE Analytical, and analyzed for total lead by USEPA Method 200.8, to meet Pennsylvania's action level requirements.

The results did not detect any exceedances at this school of the Pennsylvania Action Level of 15 micrograms per liter (ug/L).

A field sketch of the sampling locations and copy of the laboratory report is attached.

Sincerely,
Langan Engineering & Environmental Services, Inc.



John V. Musco
Associate

Enclosure

cc: R. Copenhaver, PG – Langan
B. Lambing. - Langan
Tyler Arinder – Langan

NJ Certificate of Authorization No. 24GA27996400

\\langan.com\data\DYL\data4\200130401\Project Data\Record Data\Reports\Day 9_6-15-19 Holicong_Warwick_Jamison\Jamison_Lead_Sampling_Memo.docx

July 02, 2019

Randy Copenhaver
Langan Engineering
2700 Kelly Road, Suite 200
Warrington, PA 18976

RE: Project: CENTRAL BUCKS SCHOOL(JAMISON)
Pace Project No.: 7094193

Dear Randy Copenhaver:

Enclosed are the analytical results for sample(s) received by the laboratory on June 18, 2019. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



John D. Stanton
john.stanton@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Bill Lambing, Langan Engineering



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: CENTRAL BUCKS SCHOOL(JAMISON)

Pace Project No.: 7094193

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL(JAMISON)
Pace Project No.: 7094193

Sample: JK		Lab ID: 7094193001	Collected: 06/15/19 08:49	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 13:42	7439-92-1	
Sample: NTR		Lab ID: 7094193002	Collected: 06/15/19 08:50	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 13:45	7439-92-1	
Sample: MOWR		Lab ID: 7094193003	Collected: 06/15/19 08:51	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 13:48	7439-92-1	
Sample: 101		Lab ID: 7094193004	Collected: 06/15/19 08:52	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 13:51	7439-92-1	
Sample: 102		Lab ID: 7094193005	Collected: 06/15/19 08:52	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 13:54	7439-92-1	
Sample: 103		Lab ID: 7094193006	Collected: 06/15/19 08:53	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 14:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL(JAMISON)
Pace Project No.: 7094193

Sample: 104	Lab ID: 7094193007	Collected: 06/15/19 08:53	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:06	7439-92-1	
Sample: 105	Lab ID: 7094193008	Collected: 06/15/19 08:54	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:15	7439-92-1	
Sample: 106	Lab ID: 7094193009	Collected: 06/15/19 08:54	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:18	7439-92-1	
Sample: 107	Lab ID: 7094193010	Collected: 06/15/19 08:55	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:21	7439-92-1	
Sample: 108	Lab ID: 7094193011	Collected: 06/15/19 08:55	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:25	7439-92-1	
Sample: HFA	Lab ID: 7094193012	Collected: 06/15/19 08:57	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL(JAMISON)
Pace Project No.: 7094193

Sample: HFB	Lab ID: 7094193013	Collected: 06/15/19 08:57	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:31	7439-92-1	
Sample: 109	Lab ID: 7094193014	Collected: 06/15/19 08:59	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:34	7439-92-1	
Sample: 112	Lab ID: 7094193015	Collected: 06/15/19 09:00	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:43	7439-92-1	
Sample: 133	Lab ID: 7094193016	Collected: 06/15/19 08:59	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 14:58	7439-92-1	
Sample: 132	Lab ID: 7094193017	Collected: 06/15/19 09:00	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 15:01	7439-92-1	
Sample: 130	Lab ID: 7094193018	Collected: 06/15/19 09:03	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 09:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL(JAMISON)

Pace Project No.: 7094193

Sample: 128	Lab ID: 7094193019	Collected: 06/15/19 09:03	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 09:27	7439-92-1	
Sample: 125A	Lab ID: 7094193020	Collected: 06/15/19 09:05	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 09:30	7439-92-1	
Sample: 125B	Lab ID: 7094193021	Collected: 06/15/19 09:05	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 09:33	7439-92-1	
Sample: 117	Lab ID: 7094193022	Collected: 06/15/19 09:06	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 09:42	7439-92-1	
Sample: 118	Lab ID: 7094193023	Collected: 06/15/19 09:06	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 09:45	7439-92-1	
Sample: 119	Lab ID: 7094193024	Collected: 06/15/19 09:07	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 09:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL(JAMISON)
Pace Project No.: 7094193

Sample: 120	Lab ID: 7094193025	Collected: 06/15/19 09:07	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 09:51	7439-92-1	
Sample: 121	Lab ID: 7094193026	Collected: 06/15/19 09:08	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:00	7439-92-1	
Sample: 122	Lab ID: 7094193027	Collected: 06/15/19 09:08	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:03	7439-92-1	
Sample: 123	Lab ID: 7094193028	Collected: 06/15/19 09:09	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:06	7439-92-1	
Sample: 124	Lab ID: 7094193029	Collected: 06/15/19 09:09	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:09	7439-92-1	
Sample: 201	Lab ID: 7094193030	Collected: 06/15/19 09:13	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL(JAMISON)

Pace Project No.: 7094193

Sample: 202	Lab ID: 7094193031	Collected: 06/15/19 09:13	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:21	7439-92-1	
Sample: 203	Lab ID: 7094193032	Collected: 06/15/19 09:14	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:24	7439-92-1	
Sample: 204	Lab ID: 7094193033	Collected: 06/15/19 09:14	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:28	7439-92-1	
Sample: 205	Lab ID: 7094193034	Collected: 06/15/19 09:15	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:31	7439-92-1	
Sample: 206	Lab ID: 7094193035	Collected: 06/15/19 09:15	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:40	7439-92-1	
Sample: 207	Lab ID: 7094193036	Collected: 06/15/19 09:16	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL(JAMISON)

Pace Project No.: 7094193

Sample: 208	Lab ID: 7094193037	Collected: 06/15/19 09:16	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 10:58	7439-92-1	
Sample: HF2A	Lab ID: 7094193038	Collected: 06/15/19 09:18	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 11:01	7439-92-1	
Sample: HF2B	Lab ID: 7094193039	Collected: 06/15/19 09:18	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 11:04	7439-92-1	
Sample: 212	Lab ID: 7094193040	Collected: 06/15/19 09:19	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 15:04	7439-92-1	
Sample: 216	Lab ID: 7094193041	Collected: 06/15/19 09:20	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 15:07	7439-92-1	
Sample: MFA	Lab ID: 7094193042	Collected: 06/15/19 09:22	Received: 06/18/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/30/19 15:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL(JAMISON)

Pace Project No.: 7094193

Sample: MFB		Lab ID: 7094193043	Collected: 06/15/19 09:22	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 15:13	7439-92-1	
Sample: 217		Lab ID: 7094193044	Collected: 06/15/19 09:24	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 15:16	7439-92-1	
Sample: 218		Lab ID: 7094193045	Collected: 06/15/19 09:24	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 15:19	7439-92-1	
Sample: 219		Lab ID: 7094193046	Collected: 06/15/19 09:25	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 15:34	7439-92-1	
Sample: 220		Lab ID: 7094193047	Collected: 06/15/19 09:25	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 15:37	7439-92-1	
Sample: 221		Lab ID: 7094193048	Collected: 06/15/19 09:27	Received: 06/18/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/30/19 15:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL(JAMISON)

Pace Project No.: 7094193

Sample: 222		Lab ID: 7094193049		Collected: 06/15/19 09:27	Received: 06/18/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8

Lead	<1.0	ug/L	1.0	1		06/30/19 15:43	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: 223		Lab ID: 7094193050		Collected: 06/15/19 09:28	Received: 06/18/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8

Lead	<1.0	ug/L	1.0	1		06/30/19 15:46	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: 224		Lab ID: 7094193051		Collected: 06/15/19 09:28	Received: 06/18/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8

Lead	<1.0	ug/L	1.0	1		06/30/19 15:49	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.