

July 17, 2019

Mike Nickerson, CHMM  
Environmental/Safety Coordinator  
Central Bucks School District  
320 West Swamp Road  
Doylestown, PA 18901

**Re: Lead in Drinking Water Sample Collection and Reporting  
Mill Creek Elementary School  
638 Bellflower Boulevard  
Warrington, PA 18976  
Bucks County, Pennsylvania**


Dear Mr. Nickerson:

This document has been prepared by Langan to provide the results of the drinking water sampling activities at the above referenced school. Langan sampled the drinking water sources (e.g. fountains, sink faucets, etc.) as identified by the Central Bucks School District facility inventory. The collected samples were sent to the Pennsylvania certified environmental laboratory, PACE Analytical, and analyzed for total lead by USEPA Method 200.8, to meet Pennsylvania's action level requirements.

The results did not detect any exceedances at this school of the Pennsylvania Action Level of 15 micrograms per liter (ug/L).

A field sketch of the sampling locations and copy of the laboratory report is attached.

Sincerely,  
**Langan Engineering & Environmental Services, Inc.**



John V. Musco  
Associate

Enclosure

cc: R. Copenhaver, PG – Langan  
B. Lambing. - Langan  
Tyler Arinder – Langan

NJ Certificate of Authorization No. 24GA27996400

\\langan.com\data\DY\data4\200130401\Project Data\Record Data\Reports\Day 4\_6-8-19\_Brcly\_Tit\_MC\Mill Creek\_Lead\_Sampling\_Memo.docx

## CERTIFICATIONS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

---

### Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)  
Pace Project No.: 7093843

Sample: M188	Lab ID: 7093843001	Collected: 06/08/19 08:46	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 19:50	7439-92-1	
<b>Sample: M174</b>	<b>Lab ID: 7093843002</b>	Collected: 06/08/19 08:41	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 19:53	7439-92-1	
<b>Sample: M173</b>	<b>Lab ID: 7093843003</b>	Collected: 06/08/19 08:42	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 20:02	7439-92-1	
<b>Sample: M172</b>	<b>Lab ID: 7093843004</b>	Collected: 06/08/19 08:43	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 20:05	7439-92-1	
<b>Sample: M171</b>	<b>Lab ID: 7093843005</b>	Collected: 06/08/19 08:44	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 20:14	7439-92-1	
<b>Sample: M145</b>	<b>Lab ID: 7093843006</b>	Collected: 06/08/19 08:48	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 20:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

Sample: M145F	Lab ID: 7093843007	Collected: 06/08/19 08:47	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 20:26	7439-92-1	
<b>Sample: M157</b>	<b>Lab ID: 7093843008</b>	Collected: 06/08/19 08:50	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.3	ug/L	1.0	1		06/19/19 20:30	7439-92-1	
<b>Sample: M155</b>	<b>Lab ID: 7093843009</b>	Collected: 06/08/19 08:49	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 20:39	7439-92-1	
<b>Sample: M158</b>	<b>Lab ID: 7093843010</b>	Collected: 06/08/19 08:51	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.0	ug/L	1.0	1		06/19/19 20:42	7439-92-1	
<b>Sample: M1591</b>	<b>Lab ID: 7093843011</b>	Collected: 06/08/19 08:52	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 20:45	7439-92-1	
<b>Sample: M1592</b>	<b>Lab ID: 7093843012</b>	Collected: 06/08/19 08:52	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 20:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

Sample: M1593		Lab ID: 7093843013		Collected: 06/08/19 08:52	Received: 06/12/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/19/19 20:51	7439-92-1	
Sample: MGF		Lab ID: 7093843014		Collected: 06/08/19 08:54	Received: 06/12/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/19/19 20:54	7439-92-1	
Sample: M143A		Lab ID: 7093843015		Collected: 06/08/19 08:56	Received: 06/12/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	1.3	ug/L	1.0	1		06/19/19 20:57	7439-92-1	
Sample: M118E		Lab ID: 7093843016		Collected: 06/08/19 08:58	Received: 06/12/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	4.4	ug/L	1.0	1		06/19/19 21:06	7439-92-1	
Sample: M118A		Lab ID: 7093843017		Collected: 06/08/19 08:58	Received: 06/12/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/19/19 21:15	7439-92-1	
Sample: M102		Lab ID: 7093843018		Collected: 06/08/19 09:10	Received: 06/12/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/19/19 21:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)  
Pace Project No.: 7093843

Sample: M103	Lab ID: 7093843019	Collected: 06/08/19 09:11	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 21:21	7439-92-1	
<b>Sample: M104</b>	<b>Lab ID: 7093843020</b>	Collected: 06/08/19 09:09	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.3	ug/L	1.0	1		06/19/19 21:24	7439-92-1	
<b>Sample: M105</b>	<b>Lab ID: 7093843021</b>	Collected: 06/08/19 09:11	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.1	ug/L	1.0	1		06/19/19 21:27	7439-92-1	
<b>Sample: M106</b>	<b>Lab ID: 7093843022</b>	Collected: 06/08/19 09:08	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.9	ug/L	1.0	1		06/19/19 21:30	7439-92-1	
<b>Sample: M107</b>	<b>Lab ID: 7093843023</b>	Collected: 06/08/19 09:07	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 21:33	7439-92-1	
<b>Sample: M109</b>	<b>Lab ID: 7093843024</b>	Collected: 06/08/19 09:06	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 21:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

Sample: M110	Lab ID: 7093843025	Collected: 06/08/19 09:04	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	5.6	ug/L	1.0	1		06/19/19 21:51	7439-92-1	
Sample: M111	Lab ID: 7093843026	Collected: 06/08/19 09:05	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:00	7439-92-1	
Sample: M112	Lab ID: 7093843027	Collected: 06/08/19 09:03	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:03	7439-92-1	
Sample: M113F	Lab ID: 7093843028	Collected: 06/08/19 09:01	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:06	7439-92-1	
Sample: M113	Lab ID: 7093843029	Collected: 06/08/19 09:14	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:09	7439-92-1	
Sample: M115	Lab ID: 7093843030	Collected: 06/08/19 09:15	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	3.2	ug/L	1.0	1		06/19/19 22:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

Sample: M116	Lab ID: 7093843031	Collected: 06/08/19 09:15	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	2.1	ug/L	1.0	1		06/19/19 22:16	7439-92-1	
Sample: M117	Lab ID: 7093843032	Collected: 06/08/19 09:16	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:19	7439-92-1	
Sample: M119	Lab ID: 7093843033	Collected: 06/08/19 09:18	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:28	7439-92-1	
Sample: M120F	Lab ID: 7093843034	Collected: 06/08/19 09:18	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:31	7439-92-1	
Sample: M121	Lab ID: 7093843035	Collected: 06/08/19 09:20	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:34	7439-92-1	
Sample: M122	Lab ID: 7093843036	Collected: 06/08/19 09:18	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	2.8	ug/L	1.0	1		06/19/19 22:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

Sample: M124	Lab ID: 7093843037	Collected: 06/08/19 09:24	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:46	7439-92-1	
Sample: M125	Lab ID: 7093843038	Collected: 06/08/19 09:27	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.8	ug/L	1.0	1		06/19/19 22:49	7439-92-1	
Sample: M126	Lab ID: 7093843039	Collected: 06/08/19 09:29	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 22:52	7439-92-1	
Sample: M127	Lab ID: 7093843040	Collected: 06/08/19 09:31	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	3.4	ug/L	1.0	1		06/19/19 22:55	7439-92-1	
Sample: M128	Lab ID: 7093843041	Collected: 06/08/19 09:30	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 23:04	7439-92-1	
Sample: M129	Lab ID: 7093843042	Collected: 06/08/19 09:32	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	3.0	ug/L	1.0	1		06/19/19 23:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)  
Pace Project No.: 7093843

Sample: M202	Lab ID: 7093843043	Collected: 06/08/19 09:57	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 23:10	7439-92-1	
<b>Sample: M203</b>	<b>Lab ID: 7093843044</b>	Collected: 06/08/19 09:58	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.8	ug/L	1.0	1		06/19/19 23:13	7439-92-1	
<b>Sample: M204</b>	<b>Lab ID: 7093843045</b>	Collected: 06/08/19 09:56	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 23:22	7439-92-1	
<b>Sample: M205</b>	<b>Lab ID: 7093843046</b>	Collected: 06/08/19 09:58	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 23:31	7439-92-1	
<b>Sample: M206</b>	<b>Lab ID: 7093843047</b>	Collected: 06/08/19 09:55	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.1	ug/L	1.0	1		06/19/19 23:40	7439-92-1	
<b>Sample: M207</b>	<b>Lab ID: 7093843048</b>	Collected: 06/08/19 09:55	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.1	ug/L	1.0	1		06/19/19 23:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

Sample: M209	Lab ID: 7093843049	Collected: 06/08/19 09:53	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	2.2	ug/L	1.0	1		06/19/19 23:46	7439-92-1	
<b>Sample: M210</b>	<b>Lab ID: 7093843050</b>	Collected: 06/08/19 09:51	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.2	ug/L	1.0	1		06/19/19 23:49	7439-92-1	
<b>Sample: M211</b>	<b>Lab ID: 7093843051</b>	Collected: 06/08/19 09:53	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 23:52	7439-92-1	
<b>Sample: M212</b>	<b>Lab ID: 7093843052</b>	Collected: 06/08/19 09:51	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 23:55	7439-92-1	
<b>Sample: M213F</b>	<b>Lab ID: 7093843053</b>	Collected: 06/08/19 09:50	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/19/19 23:58	7439-92-1	
<b>Sample: M213</b>	<b>Lab ID: 7093843055</b>	Collected: 06/08/19 09:48	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.6	ug/L	1.0	1		06/20/19 00:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

Sample: M214	Lab ID: 7093843056	Collected: 06/08/19 09:49	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	2.0	ug/L	1.0	1		06/20/19 00:04	7439-92-1	
<b>Sample: M215</b>	<b>Lab ID: 7093843057</b>	Collected: 06/08/19 09:47	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/20/19 00:19	7439-92-1	
<b>Sample: M216</b>	<b>Lab ID: 7093843058</b>	Collected: 06/08/19 09:47	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/20/19 00:22	7439-92-1	
<b>Sample: M217</b>	<b>Lab ID: 7093843059</b>	Collected: 06/08/19 09:46	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.1	ug/L	1.0	1		06/20/19 00:26	7439-92-1	
<b>Sample: M219</b>	<b>Lab ID: 7093843060</b>	Collected: 06/08/19 09:37	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		06/20/19 00:28	7439-92-1	
<b>Sample: M220</b>	<b>Lab ID: 7093843061</b>	Collected: 06/08/19 09:37	Received: 06/12/19 11:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8							
Lead	1.7	ug/L	1.0	1		06/20/19 00:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

Sample: M220F		Lab ID: 7093843062	Collected: 06/08/19 09:35	Received: 06/12/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/20/19 00:35	7439-92-1	
Sample: M221		Lab ID: 7093843063	Collected: 06/08/19 09:39	Received: 06/12/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/20/19 00:38	7439-92-1	
Sample: M222		Lab ID: 7093843064	Collected: 06/08/19 09:38	Received: 06/12/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/20/19 00:41	7439-92-1	
Sample: M224		Lab ID: 7093843065	Collected: 06/08/19 09:40	Received: 06/12/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	4.3	ug/L	1.0	1		06/20/19 00:44	7439-92-1	
Sample: M225		Lab ID: 7093843066	Collected: 06/08/19 09:41	Received: 06/12/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		06/20/19 17:28	7439-92-1	
Sample: M226		Lab ID: 7093843067	Collected: 06/08/19 09:42	Received: 06/12/19 11:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8						
Lead	1.6	ug/L	1.0	1		06/20/19 17:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (MILL CR)

Pace Project No.: 7093843

Sample: M227		Lab ID: 7093843068		Collected: 06/08/19 09:44	Received: 06/12/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS Drinking Water** Analytical Method: EPA 200.8

Lead	1.0	ug/L	1.0	1		06/20/19 17:40	7439-92-1	
------	-----	------	-----	---	--	----------------	-----------	--

Sample: M228		Lab ID: 7093843069		Collected: 06/08/19 09:43	Received: 06/12/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS Drinking Water** Analytical Method: EPA 200.8

Lead	<1.0	ug/L	1.0	1		06/20/19 17:43	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: M229		Lab ID: 7093843070		Collected: 06/08/19 09:44	Received: 06/12/19 11:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

**200.8 MET ICPMS Drinking Water** Analytical Method: EPA 200.8

Lead	1.6	ug/L	1.0	1		06/20/19 17:46	7439-92-1	
------	-----	------	-----	---	--	----------------	-----------	--

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.