

June 24, 2020

Mike Nickerson, CHMM
Environmental/Safety Coordinator
Central Bucks School District
320 West Swamp Road
Doylestown, PA 18901

**Re: Lead in Drinking Water Sample Collection and Reporting
Mill Creek Elementary School
638 Bellflower Boulevard
Warrington, PA 18976
Bucks County, Pennsylvania**

Dear Mr. Nickerson:

This document has been prepared by Langan to provide the results of the drinking water sampling activities at the above referenced school. Langan sampled the drinking water sources (e.g. fountains, sink faucets, etc.) on May 29, 2020 as identified by the Central Bucks School District facility inventory. The collected samples were sent to the Pennsylvania certified environmental laboratory, PACE Analytical, and analyzed for total lead by USEPA Method 200.8, to meet Pennsylvania's action level requirements.


The results did not detect any exceedances at this school of the Pennsylvania Action Level of 15 micrograms per liter (ug/L).

Also, as requested by CBSD, below is a location with a lead result above 10 ug/L, but below Pennsylvania Action Level of 15 ug/L:

<u>Location</u>	<u>Sample ID</u>	<u>Result</u>
Rm 213	M213-20	11.5 ug/L

A field sketch of the sampling locations and copy of the laboratory report is attached.

Sincerely,
Langan Engineering & Environmental Services, Inc.


John V. Musco
Associate

Enclosure

cc: B. Lambing - Langan

\\Langan.com\data\DY\l\data4\200130402\Project Data\Record Data\Reports\Day 3_5-29-2020_Pine Run_Butler_Mill Creek\Mill Creek\Mill Creek_Lead_Sampling_Memo.docx

June 08, 2020

Bill Lambing
Langan Engineering
2700 Kelly Road
Suite 200
Warrington, PA 18976

RE: Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Dear Bill Lambing:

Enclosed are the analytical results for sample(s) received by the laboratory on May 30, 2020. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Sophia Sparkes
sophia.sparkes@pacelabs.com
(631)694-3040
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: CENTRAL BUCKS DIST-MILL CREEK

Pace Project No.: 70132688

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M188-20	Lab ID: 70132688001	Collected: 05/29/20 08:40	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		06/05/20 19:27	7439-92-1	

Sample: M174-20	Lab ID: 70132688002	Collected: 05/29/20 08:41	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.3	ug/L	1.0	1		06/05/20 19:30	7439-92-1	

Sample: M173-20	Lab ID: 70132688003	Collected: 05/29/20 08:41	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.0	ug/L	1.0	1		06/05/20 19:31	7439-92-1	

Sample: M172-20	Lab ID: 70132688004	Collected: 05/29/20 08:43	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.1	ug/L	1.0	1		06/05/20 19:33	7439-92-1	

Sample: M171-20	Lab ID: 70132688005	Collected: 05/29/20 08:44	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.0	ug/L	1.0	1		06/05/20 19:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M145-20	Lab ID: 70132688006	Collected: 05/29/20 08:46	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		06/05/20 19:35	7439-92-1	
Sample: M145F-20	Lab ID: 70132688007	Collected: 05/29/20 08:46	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 19:36	7439-92-1	
Sample: M157-20	Lab ID: 70132688008	Collected: 05/29/20 08:48	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		06/05/20 19:37	7439-92-1	
Sample: M155-20	Lab ID: 70132688009	Collected: 05/29/20 08:47	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 19:38	7439-92-1	
Sample: M158-20	Lab ID: 70132688010	Collected: 05/29/20 08:49	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.2	ug/L	1.0	1		06/05/20 19:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M1591-20	Lab ID: 70132688011	Collected: 05/29/20 08:50	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		06/05/20 19:42	7439-92-1	

Sample: M1592-20	Lab ID: 70132688012	Collected: 05/29/20 08:50	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		06/05/20 19:43	7439-92-1	

Sample: M1593-20	Lab ID: 70132688013	Collected: 05/29/20 08:50	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.4	ug/L	1.0	1		06/05/20 19:45	7439-92-1	

Sample: MGF-20	Lab ID: 70132688014	Collected: 05/29/20 08:51	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 19:48	7439-92-1	

Sample: M143A-20	Lab ID: 70132688015	Collected: 05/29/20 08:53	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 19:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M118E-20	Lab ID: 70132688016	Collected: 05/29/20 08:56	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 19:52	7439-92-1	

Sample: M118A-20	Lab ID: 70132688017	Collected: 05/29/20 08:56	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		06/05/20 19:53	7439-92-1	

Sample: M102-20	Lab ID: 70132688018	Collected: 05/29/20 09:06	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 19:54	7439-92-1	

Sample: M103-20	Lab ID: 70132688019	Collected: 05/29/20 09:06	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.9	ug/L	1.0	1		06/05/20 19:55	7439-92-1	

Sample: M104-20	Lab ID: 70132688020	Collected: 05/29/20 09:05	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.2	ug/L	1.0	1		06/05/20 19:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M105-20	Lab ID: 70132688021	Collected: 05/29/20 09:05	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		06/05/20 19:56	7439-92-1	
Sample: M106-20	Lab ID: 70132688022	Collected: 05/29/20 09:04	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.8	ug/L	1.0	1		06/05/20 19:57	7439-92-1	
Sample: M107-20	Lab ID: 70132688023	Collected: 05/29/20 09:03	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.3	ug/L	1.0	1		06/05/20 19:58	7439-92-1	
Sample: M109-20	Lab ID: 70132688024	Collected: 05/29/20 09:00	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.4	ug/L	1.0	1		06/05/20 20:03	7439-92-1	
Sample: M110-20	Lab ID: 70132688025	Collected: 05/29/20 09:01	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.7	ug/L	1.0	1		06/05/20 20:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M111-20	Lab ID: 70132688026	Collected: 05/29/20 08:59	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.9	ug/L	1.0	1		06/05/20 20:05	7439-92-1	
Sample: M112-20	Lab ID: 70132688027	Collected: 05/29/20 09:01	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.3	ug/L	1.0	1		06/05/20 20:06	7439-92-1	
Sample: M113F-20	Lab ID: 70132688028	Collected: 05/29/20 08:58	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 20:07	7439-92-1	
Sample: M113-20	Lab ID: 70132688029	Collected: 05/29/20 08:58	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 20:08	7439-92-1	
Sample: M115-20	Lab ID: 70132688030	Collected: 05/29/20 09:09	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 20:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M116-20	Lab ID: 70132688031	Collected: 05/29/20 09:09	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.2	ug/L	1.0	1		06/05/20 20:09	7439-92-1	

Sample: M117-20	Lab ID: 70132688032	Collected: 05/29/20 09:09	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 20:10	7439-92-1	

Sample: M119-20	Lab ID: 70132688033	Collected: 05/29/20 09:12	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.8	ug/L	1.0	1		06/05/20 20:15	7439-92-1	

Sample: M120F-20	Lab ID: 70132688034	Collected: 05/29/20 09:10	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 20:18	7439-92-1	

Sample: M121-20	Lab ID: 70132688035	Collected: 05/29/20 09:12	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		06/05/20 20:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M122-20	Lab ID: 70132688036	Collected: 05/29/20 09:12	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.3	ug/L	1.0	1		06/05/20 20:20	7439-92-1	

Sample: M124-20	Lab ID: 70132688037	Collected: 05/29/20 09:13	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.1	ug/L	1.0	1		06/05/20 20:21	7439-92-1	

Sample: M125-20	Lab ID: 70132688038	Collected: 05/29/20 09:13	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.4	ug/L	1.0	1		06/05/20 20:22	7439-92-1	

Sample: M126-20	Lab ID: 70132688039	Collected: 05/29/20 09:15	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.0	ug/L	1.0	1		06/05/20 20:23	7439-92-1	

Sample: M127-20	Lab ID: 70132688040	Collected: 05/29/20 09:15	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		06/05/20 20:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M128-20	Lab ID: 70132688041	Collected: 05/29/20 09:15	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.0	ug/L	1.0	1		06/05/20 20:26	7439-92-1	

Sample: M129-20	Lab ID: 70132688042	Collected: 05/29/20 09:15	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.1	ug/L	1.0	1		06/05/20 20:27	7439-92-1	

Sample: M202-20	Lab ID: 70132688043	Collected: 05/29/20 09:36	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.8	ug/L	1.0	1		06/05/20 20:28	7439-92-1	

Sample: M203-20	Lab ID: 70132688044	Collected: 05/29/20 09:36	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.6	ug/L	1.0	1		06/05/20 20:31	7439-92-1	

Sample: M204-20	Lab ID: 70132688045	Collected: 05/29/20 09:35	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.0	ug/L	1.0	1		06/05/20 20:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M205-20	Lab ID: 70132688046	Collected: 05/29/20 09:35	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.7	ug/L	1.0	1		06/05/20 20:33	7439-92-1	

Sample: M206-20	Lab ID: 70132688047	Collected: 05/29/20 09:33	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		06/05/20 20:34	7439-92-1	

Sample: M207-20	Lab ID: 70132688048	Collected: 05/29/20 09:33	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		06/05/20 20:37	7439-92-1	

Sample: M209-20	Lab ID: 70132688049	Collected: 05/29/20 09:31	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.1	ug/L	1.0	1		06/05/20 20:37	7439-92-1	

Sample: M210-20	Lab ID: 70132688050	Collected: 05/29/20 09:31	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.6	ug/L	1.0	1		06/05/20 20:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M211-20	Lab ID: 70132688051	Collected: 05/29/20 09:31	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		06/05/20 20:39	7439-92-1	
Sample: M212-20	Lab ID: 70132688052	Collected: 05/29/20 09:31	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.2	ug/L	1.0	1		06/05/20 20:40	7439-92-1	
Sample: M213F-20	Lab ID: 70132688053	Collected: 05/29/20 09:30	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 20:43	7439-92-1	
Sample: M213-20	Lab ID: 70132688054	Collected: 05/29/20 09:28	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	11.5	ug/L	1.0	1		06/05/20 20:48	7439-92-1	
Sample: M214-20	Lab ID: 70132688055	Collected: 05/29/20 09:34	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.4	ug/L	1.0	1		06/05/20 20:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M215-20	Lab ID: 70132688056	Collected: 05/29/20 09:29	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.6	ug/L	1.0	1		06/05/20 20:50	7439-92-1	
Sample: M216-20	Lab ID: 70132688057	Collected: 05/29/20 09:28	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		06/05/20 20:51	7439-92-1	
Sample: M217-20	Lab ID: 70132688058	Collected: 05/29/20 09:28	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	9.9	ug/L	1.0	1		06/05/20 20:52	7439-92-1	
Sample: M219-20	Lab ID: 70132688059	Collected: 05/29/20 09:20	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.1	ug/L	1.0	1		06/05/20 20:53	7439-92-1	
Sample: M220-20	Lab ID: 70132688060	Collected: 05/29/20 09:20	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		06/05/20 20:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M220F-20	Lab ID: 70132688061	Collected: 05/29/20 09:19	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		06/05/20 20:54	7439-92-1	

Sample: M221-20	Lab ID: 70132688062	Collected: 05/29/20 09:21	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		06/05/20 20:56	7439-92-1	

Sample: M222-20	Lab ID: 70132688063	Collected: 05/29/20 09:21	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.0	ug/L	1.0	1		06/05/20 20:56	7439-92-1	

Sample: M224-20	Lab ID: 70132688064	Collected: 05/29/20 09:23	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.8	ug/L	1.0	1		06/05/20 21:01	7439-92-1	

Sample: M225-20	Lab ID: 70132688065	Collected: 05/29/20 09:23	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.5	ug/L	1.0	1		06/05/20 21:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Sample: M226-20	Lab ID: 70132688066	Collected: 05/29/20 09:24	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.4	ug/L	1.0	1		06/05/20 21:03	7439-92-1	

Sample: M227-20	Lab ID: 70132688067	Collected: 05/29/20 09:24	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.8	ug/L	1.0	1		06/05/20 21:04	7439-92-1	

Sample: M228-20	Lab ID: 70132688068	Collected: 05/29/20 09:25	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		06/05/20 21:05	7439-92-1	

Sample: M229-20	Lab ID: 70132688069	Collected: 05/29/20 09:25	Received: 05/30/20 16:53	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		06/05/20 21:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: CENTRAL BUCKS DIST-MILL CREEK

Pace Project No.: 70132688

QC Batch:	163355	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70132688001, 70132688002, 70132688003, 70132688004, 70132688005, 70132688006, 70132688007, 70132688008, 70132688009, 70132688010, 70132688011, 70132688012

METHOD BLANK: 787080 Matrix: Water

Associated Lab Samples: 70132688001, 70132688002, 70132688003, 70132688004, 70132688005, 70132688006, 70132688007, 70132688008, 70132688009, 70132688010, 70132688011, 70132688012

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/05/20 19:25	

LABORATORY CONTROL SAMPLE: 787081

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.2	98	85-115	

MATRIX SPIKE SAMPLE: 787085

Parameter	Units	70132688003 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.0	4	8.2	104	70-130	

SAMPLE DUPLICATE: 787084

Parameter	Units	70132688003 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	4.0	4.0	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: CENTRAL BUCKS DIST-MILL CREEK

Pace Project No.: 70132688

QC Batch:	163357	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70132688013, 70132688014, 70132688015, 70132688016, 70132688017, 70132688018, 70132688019, 70132688020, 70132688021, 70132688022, 70132688023, 70132688024, 70132688025, 70132688026, 70132688027, 70132688028, 70132688029, 70132688030, 70132688031, 70132688032		

METHOD BLANK:	787090	Matrix:	Water
Associated Lab Samples:	70132688013, 70132688014, 70132688015, 70132688016, 70132688017, 70132688018, 70132688019, 70132688020, 70132688021, 70132688022, 70132688023, 70132688024, 70132688025, 70132688026, 70132688027, 70132688028, 70132688029, 70132688030, 70132688031, 70132688032		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/05/20 19:44	

LABORATORY CONTROL SAMPLE: 787091

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.8	98	85-115	

MATRIX SPIKE SAMPLE: 787093

Parameter	Units	70132688013 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.4	4	7.2	120	70-130	

MATRIX SPIKE SAMPLE: 787095

Parameter	Units	70132688023 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.3	4	7.6	110	70-130	

SAMPLE DUPLICATE: 787092

Parameter	Units	70132688013 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.4	2.3	3	

SAMPLE DUPLICATE: 787094

Parameter	Units	70132688023 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.3	3.4	3	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

QC Batch:	163359	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70132688033, 70132688034, 70132688035, 70132688036, 70132688037, 70132688038, 70132688039, 70132688040, 70132688041, 70132688042, 70132688043, 70132688044, 70132688045, 70132688046, 70132688047, 70132688048, 70132688049, 70132688050, 70132688051, 70132688052

METHOD BLANK: 787101 Matrix: Water
Associated Lab Samples: 70132688033, 70132688034, 70132688035, 70132688036, 70132688037, 70132688038, 70132688039, 70132688040, 70132688041, 70132688042, 70132688043, 70132688044, 70132688045, 70132688046, 70132688047, 70132688048, 70132688049, 70132688050, 70132688051, 70132688052

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/05/20 20:11	

LABORATORY CONTROL SAMPLE: 787102

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.0	98	85-115	

MATRIX SPIKE SAMPLE: 787104

Parameter	Units	70132688033 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	8.8	4	13.1	108	70-130	

MATRIX SPIKE SAMPLE: 787106

Parameter	Units	70132688043 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.8	4	6.9	102	70-130	

SAMPLE DUPLICATE: 787103

Parameter	Units	70132688033 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	8.8	8.8	1	

SAMPLE DUPLICATE: 787105

Parameter	Units	70132688043 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.8	2.9	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

QC Batch:	163360	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70132688053, 70132688054, 70132688055, 70132688056, 70132688057, 70132688058, 70132688059, 70132688060, 70132688061, 70132688062, 70132688063, 70132688064, 70132688065, 70132688066, 70132688067, 70132688068, 70132688069

METHOD BLANK: 787108 Matrix: Water
Associated Lab Samples: 70132688053, 70132688054, 70132688055, 70132688056, 70132688057, 70132688058, 70132688059, 70132688060, 70132688061, 70132688062, 70132688063, 70132688064, 70132688065, 70132688066, 70132688067, 70132688068, 70132688069

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/05/20 20:41	

LABORATORY CONTROL SAMPLE: 787109

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	47.2	94	85-115	

MATRIX SPIKE SAMPLE: 787111

Parameter	Units	70132688053 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	4	4.1	100	70-130	

MATRIX SPIKE SAMPLE: 787113

Parameter	Units	70132688063 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.0	4	5.2	105	70-130	

SAMPLE DUPLICATE: 787110

Parameter	Units	70132688053 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 787112

Parameter	Units	70132688063 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.0	1.1	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: CENTRAL BUCKS DIST-MILL CREEK

Pace Project No.: 70132688

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CENTRAL BUCKS DIST-MILL CREEK

Pace Project No.: 70132688

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70132688001	M188-20	EPA 200.8	163355		
70132688002	M174-20	EPA 200.8	163355		
70132688003	M173-20	EPA 200.8	163355		
70132688004	M172-20	EPA 200.8	163355		
70132688005	M171-20	EPA 200.8	163355		
70132688006	M145-20	EPA 200.8	163355		
70132688007	M145F-20	EPA 200.8	163355		
70132688008	M157-20	EPA 200.8	163355		
70132688009	M155-20	EPA 200.8	163355		
70132688010	M158-20	EPA 200.8	163355		
70132688011	M1591-20	EPA 200.8	163355		
70132688012	M1592-20	EPA 200.8	163355		
70132688013	M1593-20	EPA 200.8	163357		
70132688014	MGF-20	EPA 200.8	163357		
70132688015	M143A-20	EPA 200.8	163357		
70132688016	M118E-20	EPA 200.8	163357		
70132688017	M118A-20	EPA 200.8	163357		
70132688018	M102-20	EPA 200.8	163357		
70132688019	M103-20	EPA 200.8	163357		
70132688020	M104-20	EPA 200.8	163357		
70132688021	M105-20	EPA 200.8	163357		
70132688022	M106-20	EPA 200.8	163357		
70132688023	M107-20	EPA 200.8	163357		
70132688024	M109-20	EPA 200.8	163357		
70132688025	M110-20	EPA 200.8	163357		
70132688026	M111-20	EPA 200.8	163357		
70132688027	M112-20	EPA 200.8	163357		
70132688028	M113F-20	EPA 200.8	163357		
70132688029	M113-20	EPA 200.8	163357		
70132688030	M115-20	EPA 200.8	163357		
70132688031	M116-20	EPA 200.8	163357		
70132688032	M117-20	EPA 200.8	163357		
70132688033	M119-20	EPA 200.8	163359		
70132688034	M120F-20	EPA 200.8	163359		
70132688035	M121-20	EPA 200.8	163359		
70132688036	M122-20	EPA 200.8	163359		
70132688037	M124-20	EPA 200.8	163359		
70132688038	M125-20	EPA 200.8	163359		
70132688039	M126-20	EPA 200.8	163359		
70132688040	M127-20	EPA 200.8	163359		
70132688041	M128-20	EPA 200.8	163359		
70132688042	M129-20	EPA 200.8	163359		
70132688043	M202-20	EPA 200.8	163359		
70132688044	M203-20	EPA 200.8	163359		
70132688045	M204-20	EPA 200.8	163359		
70132688046	M205-20	EPA 200.8	163359		
70132688047	M206-20	EPA 200.8	163359		
70132688048	M207-20	EPA 200.8	163359		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CENTRAL BUCKS DIST-MILL CREEK
Pace Project No.: 70132688

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70132688049	M209-20	EPA 200.8	163359		
70132688050	M210-20	EPA 200.8	163359		
70132688051	M211-20	EPA 200.8	163359		
70132688052	M212-20	EPA 200.8	163359		
70132688053	M213F-20	EPA 200.8	163360		
70132688054	M213-20	EPA 200.8	163360		
70132688055	M214-20	EPA 200.8	163360		
70132688056	M215-20	EPA 200.8	163360		
70132688057	M216-20	EPA 200.8	163360		
70132688058	M217-20	EPA 200.8	163360		
70132688059	M219-20	EPA 200.8	163360		
70132688060	M220-20	EPA 200.8	163360		
70132688061	M220F-20	EPA 200.8	163360		
70132688062	M221-20	EPA 200.8	163360		
70132688063	M222-20	EPA 200.8	163360		
70132688064	M224-20	EPA 200.8	163360		
70132688065	M225-20	EPA 200.8	163360		
70132688066	M226-20	EPA 200.8	163360		
70132688067	M227-20	EPA 200.8	163360		
70132688068	M228-20	EPA 200.8	163360		
70132688069	M229-20	EPA 200.8	163360		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.