

August 24, 2021

Thomas M. Hanna, P.E., LEED AP  
Capital Projects Manager  
Central Bucks School District  
320 West Swamp Road  
Doylestown, PA 18901

**Re: Lead in Drinking Water Re-Sample Collection and Reporting  
Central Bucks West High School  
375 W Court Street  
Doylestown, PA 18901**


Dear Mr. Hanna:

This document has been prepared by Langan to the results of the drinking water re-sampling activities at the above referenced school. The results of the initial drinking water sampling activities documented that total lead was present in one sample collected from a drinking water fixture (Sample Location F141B) at a level above the 15 micrograms per liter (ug/L) regulatory level. The re-sampling was conducted on August 12, 2021 after the fixture was flushed. The collected sample was sent to the Pennsylvania certified environmental laboratory, PACE Analytical, and analyzed for total lead by USEPA Method 200.8, to meet Pennsylvania's action level requirements.

The re-sampling result did not detect an exceedance of the Pennsylvania Action Level of 15 ug/L.

A figure of the re-sampling location and copy of the laboratory report is attached.

Sincerely,  
**Langan Engineering & Environmental Services, Inc.**



John V. Musco  
Associate

Enclosure  
cc: B. Lambing - Langan

NJ Certificate of Authorization No. 24GA27996400

\\langan.com\data\DY\data4\200130403\Project Data\Record Data\Reports\Resampling August 2021\Resampling Report\West\West HS\_Lead\_Re-Sampling\_Report\_2021.docx

August 18, 2021

Bill Lambing  
Langan Engineering  
2700 Kelly Road  
Suite 200  
Warrington, PA 18976

RE: Project: CENTRAL BUCKS SCHOOL (CB WEST)  
Pace Project No.: 70184243

Dear Bill Lambing:

Enclosed are the analytical results for sample(s) received by the laboratory on August 14, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Sophia Sparkes  
sophia.sparkes@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: CENTRAL BUCKS SCHOOL (CB WEST)

Pace Project No.: 70184243

---

### **Pace Analytical Services Long Island**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: CENTRAL BUCKS SCHOOL (CB WEST)  
Pace Project No.: 70184243

Sample: F141BR_081121	Lab ID: 70184243001	Collected: 08/11/21 06:55	Received: 08/14/21 10:40	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>5.8</b>	ug/L	1.0	1		08/17/21 16:42	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: CENTRAL BUCKS SCHOOL (CB WEST)  
Pace Project No.: 70184243

QC Batch: 222171	Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8	Analysis Description: 200.8 MET No Prep Drinking Water
	Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70184243001

METHOD BLANK: 1120306 Matrix: Water  
Associated Lab Samples: 70184243001

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	08/17/21 16:33	

LABORATORY CONTROL SAMPLE: 1120307

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.6	101	85-115	

MATRIX SPIKE SAMPLE: 1120310

Parameter	Units	70183854001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.2	50	71.5	129	70-130	

MATRIX SPIKE SAMPLE: 1120312

Parameter	Units	70184245003 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	48.8	50	110	122	70-130	

SAMPLE DUPLICATE: 1120309

Parameter	Units	70183854001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	7.2	7.0	2	

SAMPLE DUPLICATE: 1120311

Parameter	Units	70184245003 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	48.8	49.4	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALIFIERS

Project: CENTRAL BUCKS SCHOOL (CB WEST)

Pace Project No.: 70184243

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CENTRAL BUCKS SCHOOL (CB WEST)

Pace Project No.: 70184243

---

<b>Lab ID</b>	<b>Sample ID</b>	<b>QC Batch Method</b>	<b>QC Batch</b>	<b>Analytical Method</b>	<b>Analytical Batch</b>
70184243001	F141BR_081121	EPA 200.8	222171		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### CHAIN-OF-CUSTODY / Analytical Request Form

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed.

**WO#: 70184243**



70184243

**Section A**

**Section B**

**Section C**

**Required Client Information:**

**Required Project Information:**

**Invoice Information:**

Company: Langan Engineering	Report To: Bill Lambing	Attention: Bill Lambing	
Address: 2700 Kelly Road, Suite 200 Warrington, PA 18976	Copy To:	Company Name: Langan Engineering	
Email: <a href="mailto:blambing@langan.com">blambing@langan.com</a>	Purchase Order #: 200130403-400-001	Address: 2700 Kelly Road, Suite 200	<b>Regulatory Agency</b>
Phone: 215-491-6500 Fax: 2015-491-6501	Project Name: Central Bucks School District (CB West)	Pace Quote: See Langan-Pace MSA	
Requested Due Date: 72 hour (3 day) Turn Around	Project #: 200130403	Pace Project Manager: sophia.sparkes@pacelabs.com	<b>State / Location</b>
		Pace Profile #: 7983	PA

ITEM #	SAMPLE ID One Character per box. (A-Z, 0-9 / , -) Sample ids must be unique	MATRIX Drinking Water Water Waste Water Product Soil/Solid Oil Wipe Air Other Tissue	CODE DW WT WW P SL OL WP AR OT TS	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED				SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives										Analyses Test Y/N	200.7 Metals (PB)	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	
						START		END				Unpreserved	H2SO4	HNO3	HCl	NaOH	Na2S2O3	Methanol	Other							
						DATE	TIME	DATE	TIME																	
1	F141BR 081121	DW	G	8/11/2021	655	8/11/2021	655		1		X														X	
2																										
3																										
4																										
5																										
6																										
7																										
8																										
9																										
10																										
11																										
12																										
ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION		DATE	TIME	ACCEPTED BY / AFFILIATION		DATE	TIME	SAMPLE CONDITIONS																
		Bill Lambing		8/12/2021	530	Kuan Am		8/14/21	10:40																	

SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER:	Bill Lambing
SIGNATURE of SAMPLER:	<i>Bill Lambing</i>
DATE Signed:	8/12/2021

TEMP in C	Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)





# Sample Condition Upon Receipt

## WO#: 70184243

PM: STS Due Date: 08/19/21  
CLIENT: LAN-PA

Client Name: \_\_\_\_\_ Project: \_\_\_\_\_

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other

Tracking #: 5295 6205 5280

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No

Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other

Thermometer Used: TH091 Correction Factor: +0.0

Cooler Temperature(°C): 21.0 Cooler Temperature Corrected(°C): 21.0

Temp should be above freezing to 6.0°C

USDA Regulated Soil (  N/A, water sample)

Temperature Blank Present:  Yes  No  
Type of Ice: Wet Blue None  
 Samples on ice, cooling process has begun  
Date/Time 5035A kits placed in freezer \_\_\_\_\_

Date and Initials of person examining contents: KO 8/14/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

			COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	10.
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	11.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: <u>SL WT OIL</u>			
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>HC55968</u>			Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NaOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis			
Samples checked for dechlorination: KI starch test strips Lot #	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #			
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #			
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____			

Client Notification/ Resolution: \_\_\_\_\_ Field Data Required? Y / N

Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_

Comments/ Resolution: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_